



DAN'S
Pre-Cast
LTD.

6100 Scott Rd.
Duncan, B.C.
V9L6G9

www.dansprecast.com
250-746-7400

Details:

1. Concrete Strength to be 32 MPa @ 28 days
2. Lid Reinforced with 15M @ 12" ea. way
3. Concrete contains MacMatrix 2" Fibers
4. Lid & Bottom sealed with Conseal CS-665
5. Inlet to be drilled through riser, 2" Outlet drain
6. 24" Polylok Riser and Lid
7. CS 600 Loading Tank & Lid Available

Total Tank Volume: 2100 Imp. Gal. Approximate Tank Weight: 17,047lbs

Date **JANUARY 22, 2018**

Drawing No. **2100 CISTERN**